



SWR Institute
400 Admiral Blvd
Kansas City, MO 64106
816.472.7974
info@swrionline.org

Product Name: DuraLink Super Adhesion Sealant

Submitted by: CHEM LINK INC
353 E Lyons St.
Schoolcraft, MI 49087
jeff@chemlink.com
www.chemlinkinc.com

Test Results

ASTM C 719 Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]
Pass: Yes
Extension: +50% Compression: -50%
Substrate: Mortar, Aluminum, Glass [Mortar substrates were primed with Chem Link Nova Prime Primer.]

Validation Date: 9/9/2013

Expiration Date: 9/8/2018

Lab Details: Architectural Testing
130 Derry Court
York, PA 17406-8405
Phone: 717.764.7700
Fax: 717.764.4129